




MH "ERS" - Matično preduzeće a.d. Trebinje
ZD "Istraživačko razvojni centar elektroenergetike" a.d.

Vuka Karadžića 17, 71123 Istočno Sarajevo; Tel/Fax: +387 (57) 342-014 ; Tel: +387 (57) 340-316 ; E-mail: irce@teol.net

Okružni privredni sud I. Sarajevo Br. 061-0-REG-12-000 387;
MBS: 89-02-0002-10 (1-113); Matični broj: 1056166;
PDV broj: 400543080007; JIB: 4400543080007;

Žiro računi:
NLB Razvojna banka a.d. B. Luka 562 012 00003124 41;
Hypo Alpe Adia Bank a.d. B. Luka 552 004 00011264 25



POTVRDA O TIPSKOM ISPITIVANJU
TYPE TEST CERTIFICATE

Br: 127/2014

No: 127/2014

Datum Date	25.03.2014.
Ispitivanje po standardu	IEC 61439-2:2011 , Stepen zaštite ormara (10.3), Izolacioni razmaci i klizne staze (10.4), Zaštita od strujnog udara i integritet zaštitnih kola (10.5), Dielektrična svojstva (10.9), Test porasta temperature (10.10), Podnosivost kratkog spoja (10.11)
Test Standard	IEC 61439-2:2011 , Degree of protection of assemblies (10.3), Clearances and creepage distances (10.4), Protection against electric shock and integrity of protective circuits (10.5), Dielectric properties (10.9), Verification of temperature rise (10.10), Short-circuit withstand strength (10.11)
Ispitivani objekat Tested subject	NN rasklopni blok tip BNN-2-12-10 Low-voltage switchgear and controlgear assemblies type BNN-2-12-10
Proizvođač Manufacturer	ENERGOTEHNIKA - JUŽNA BAČKA d.o.o , Novi Sad, Srbija
Naručilac Customer	ENERGOTEHNIKA - JUŽNA BAČKA d.o.o , Novi Sad, Srbija
Rezultati ispitivanja su dati u	Ispitni izvještaj br. 63-127/2014 , datum 25.03.2014.
Test results are given in	Test Report No. 63-127/2014 , date 25.03.2014.
Atest vrijedi do Certificate is valid until	Promjene materijala ili konstrukcije Change of materials or construction
ZAKLJUČAK:	NN rasklopni blok tip BNN-2-12-10 je zadovoljio ispitivanja u skladu sa standardom IEC 61439-2:2011.
CONCLUSION:	Low-voltage switchgear and controlgear assemblies type BNN-2-12-10 fulfilled the requirements in accordance with IEC 61439-2:2011 and passed the test successfully.



Manager of MH 'ERS' ZD IRCE a.d.

(M. Sc. Lazar Sikimić B. E. E.)